






Presjek A-A
TELESKOPSKA KLIZNA
GRLA HODA 300 mm



Regulacija kliznih
grla vijcima M12x25


Detalj B
Mjerilo 1:5



Polipropilenski
koalescentni
uložak

Separatori spadaju u I. klasu separatora prema hrvatskoj normi HRN EN 858 što znači da je količina rezidualnog ulja manja od 5 mg/l

Volumen separatora: 50000 l
Protok separatora: 250 l/s
Cijevi: Ø600
Masa praznog separatora: 10300kg
Masa punog separatora: 55000kg



Čelčni
anker

AB podloga

Površina		Mjerilo	1:60	Pozicija	-	Masa	-
-							

Ime	Datum	Potpis
Čiao		
Levačić Ildiriping, str.		
Prekonič		
Horvat D.maring, mech.		
Odobrio		
Horvat Dj, str.leh, acc		

Separator 50000

Q=250 lit/sec

Ime	Datum	Potpis
Čiao		
Levačić Ildiriping, str.		
Prekonič		
Horvat D.maring, mech.		
Odobrio		
Horvat Dj, str.leh, acc		

Rehnix

TX-DK-D-1907-SEP-50000-S1

redbrl	Promjena	Datum	Ime	Spremljeno	TX-DK-D-1907-SEP-50000-S1
5					